



SUPPORTING DOCUMENT **PRE HOT WORK CHECK LIST**

Before hot work is permitted and at least once per day while the permit is in effect, the area shall be inspected by the individual responsible for authorizing hot work operations to ensure that it is a fire safe area.

A pre hot work check is required prior to commencing hot work to ensure all equipment is safe and hazards are recognized and protected. A report of the check shall be kept at the work site during the work and available upon request.

- Hot work equipment to be used shall be in satisfactory operating condition and in good repair.
- Hot work site is clear of combustible or combustibles are protected.
- Exposed construction is of noncombustible materials or, if combustible, then protected.
- Openings are protected.
- Floors are kept clean.
- No exposed combustible are located on the opposite side of partitions, walls, ceilings or floors.
- Fire watches, where required, are assigned.
- Approved actions have been taken to prevent accidental activation of suppression and detection equipment in accordance with Section 3504.1.8 and 3504.1.9
- Fire extinguishers and fire hoses (where provided) are operable and available.
- A minimum of one 2A:20B:C portable fire extinguisher which has been serviced within the last 12 months.