



## ADDENDUM #2 REQUEST FOR PROPOSAL 2016-110

### KITSAP COUNTY FACILITIES FAIRGROUND PAVILION HVAC REPLACEMENT

**TO:** All Respondents  
**FROM:** Colby Wattling, Buyer  
**CLOSING DATE:** February 25, 2016 at 2:00 PM (UNCHANGED)  
**REF NO.:** 2016-110 IFB Fairground Pavilion HVAC Replacement  
**DATE:** February 17, 2016

---

The following are responses to the questions asked during the site visit on February 17, 2016.

**Q1: Are they electric or gas units?**

**A1: Electric.**

**Q2: Are they just cooling units?**

**A2: Yes.**

**Q3: Which units are they?**

**A3: The two middle units on the south part of the roof.**

**Q4: Is cleaning the ducts part of this bid?**

**A4: No.**

**Q5: What is the budget for this job?**

**A5: \$45,000 with everything including tax.**

**Q6: What is the timeline for the project to be completed?**

**A6: Typically within 60 days of the contract signing.**

**Q7: Concern – shipping can take 6-8 weeks is there wiggle room in that timeline?**

**A7: Yes, we can negotiate this.**

**Q8: Are we supposed to supply new electric disconnects?**

**A8: Preferably, yes.**

**Q9: Wiring – is the metal conduit acting as a ground wire?**

**A9: Yes, it goes from the switch gear to the unit.**

**Q10: Is there a main ground wire?**

**A10: No, see above.**

**Q11: What is the wire size?**

**A11: 6 gauge.**

**Q12: What size fuses?**

**A12: 50 amp fuses max.**

There are no other changes to the original specifications other than what is changed by Addendum 2 and Acknowledgement of receipt of this and all ADDENDA are required.

END OF ADDENDUM #2