



## **ADDENDUM #3 REQUEST FOR PROPOSAL 2016-110**

### **KITSAP COUNTY FACILITIES FAIRGROUND PAVILION HVAC REPLACEMENT**

**TO:** All Respondents  
**FROM:** Colby Wattling, Buyer  
**CLOSING DATE:** February 25, 2016 at 2:00 PM (UNCHANGED)  
**REF NO.:** 2016-110 IFB Fairground Pavilion HVAC Replacement  
**DATE:** February 24, 2016

---

An issue with the existing curb unit has been found. Below is the issue along with how to address it.

**Existing roof top units sit on a factory curb designed specifically for that unit. The preferred remedy to this is to use a curb adapter to be mounted on existing curb, then matching the new unit to existing curb supply and return air duct.**

There are no other changes to the original specifications other than what is changed by Addendum 3 and Acknowledgement of receipt of this and all ADDENDA are required.

END OF ADDENDUM #3