



ADDENDUM #1 INFORMAL BID 2016-129

KITSAP COUNTY PARKS AND RECREATION WHITE HOUSE AND PRESIDENTS HALL REPAVING

TO: All Respondents
FROM: Colby Wattling, Buyer
CLOSING DATE: APRIL 26, 2016 at 3:00PM (UNCHANGED)
REF NO.: 2016-129 IFB
DATE: April 14, 2016

The following are **questions** and **answers** asked during the April 14, 2016 site walk. Also included is the overhead view mentioned in Question 4.

- Q1. What is the depth of the asphalt to be laid?**
A1: 2 inches, to match the rest of the fairgrounds pavement.
- Q2. Will the waste be left on site?**
A2: Yes, please grind the waste and put it on the road at the lower bowl.
- Q3. Will the waste need to be graded after it is laid?**
A3 No, fairgrounds staff will do so, it should be offloaded so that it is spread.
- Q4. Today's two locations shown appear to be less than 19,500 Sq. Ft, will there be additional areas?**
A4: A third area was toured (Dog Barn) an overhead view of all three areas is provided. The budget allows for 19,500 Sq. Ft.



There are no other changes to the original specifications other than what is changed by Addendum 1.
Acknowledgement of receipt of this and all ADDENDA are required
END OF ADDENDUM #1